Q

	Application No.	Applicant(s)
Notice of Allowability	10/808,491	FRUTSCHI ET AL.
	Examiner	Art Unit
	Ted Kim	3746
The MAILING DATE of this communication appear All claims being allowable, PROSECUTION ON THE MERITS IS herewith (or previously mailed), a Notice of Allowance (PTOL-85) NOTICE OF ALLOWABILITY IS NOT A GRANT OF PATENT RI of the Office or upon petition by the applicant. See 37 CFR 1.313	(OR REMAINS) CLOSED in this app or other appropriate communication IGHTS. This application is subject to	olication. If not included will be mailed in due course. THIS
1. This communication is responsive to <u>03/29/2005</u> .		
2. The allowed claim(s) is/are <u>1-25</u> .		
3. $\square$ The drawings filed on $\underline{03/09/2005~\&~03/25/2004}$ are accept	ted by the Examiner.	
4.		
Attachment(s)  1. Notice of References Cited (PTO-892)  2. Notice of Draftperson's Patent Drawing Review (PTO-948)  3. Information Disclosure Statements (PTO-1449 or PTO/SB/0 Paper No./Mail Date  4. Examiner's Comment Regarding Requirement for Deposit of Biological Material	6. ☐ Interview Summary Paper No./Mail Date 8), 7. ☑ Examiner's Amendm	ė

Application/Control Number: 10/808,491 Page 2

Art Unit: 3746

## **EXAMINER'S AMENDMENT**

1. An examiner's amendment to the record appears below. Should the changes and/or additions be unacceptable to applicant, an amendment may be filed as provided by 37 CFR 1.312. To ensure consideration of such an amendment, it MUST be submitted no later than the payment of the issue fee.

Authorization for this examiner's amendment was given in a telephone interview with Adam Cermak on 4/26/05.

The application has been amended as follows:

## **CLAIMS**

- Claim 4, line 4, "compression," has been replaced by compression or -
- Claim 10, line 10, "upstream," has been replaced by upstream or --.

## REASONS FOR ALLOWANCE

2. The following is an examiner's statement of reasons for allowance: the prior art of record do not fairly teach in permissible combination the claimed invention. In particular, the prior art of record do not fairly teach "a power generation plant comprising: at least one gas turbine cycle including a heat-recovery boiler and at least one steam turbine cycle in communication with the heat-recovery boiler, the gas turbine cycle being semi-closed and substantially free of emissions, the gas turbine cycle comprising a compressor, a combustion chamber arranged downstream of the compressor, a gas turbine arranged downstream of the combustion chamber, a heat-recovery boiler arranged downstream of the gas turbine, a hot-gas path between the gas

Art Unit: 3746

turbine and the heat-recovery boiler, an exhaust-gas path downstream of the heat-recovery boiler, and at least one generator coupled to the gas turbine; first means for alternatively or additionally allowing hot gas to be fed into said hot-gas path; and second means for alternatively or additionally allowing exhaust gas to be expelled from the exhaust-gas path." Note that semi-closed gas turbine cycles with steam cycles are known, e.g. WO 01/90548 or EP 0939199, the combination of the first means for alternatively or additionally allowing hot gas to be fed into said hot-gas path (see e.g.; and second means for alternatively or additionally allowing exhaust gas to be expelled from the exhaust-gas path with the rest of the claim limitations renders the claims distinct from the art of record.

Any comments considered necessary by applicant must be submitted no later than the payment of the issue fee and, to avoid processing delays, should preferably accompany the issue fee. Such submissions should be clearly labeled "Comments on Statement of Reasons for Allowance."

## **Contact Information**

Any inquiry concerning this communication or earlier communications from the Examiner should be directed to Ted Kim whose telephone number is 571-272-4829. The Examiner can be reached on regular business hours before 5:00 pm, Monday to Thursday and every other Friday.

Application/Control Number: 10/808,491

Art Unit: 3746

The fax numbers for the organization where this application is assigned are 703-872-9306 for Regular faxes and 703-872-9306 for After Final faxes.

If attempts to reach the examiner by telephone are unsuccessful, the examiner's supervisor, Cheryl Tyler, can be reached on 571-272-4834.

Any inquiry of a general nature or relating to the status of this application or proceeding should be directed to the receptionist of Technology Center 3700, whose telephone number is 703-308-0861. General inquiries can also be directed to the Patents Assistance Center whose telephone number is 800-786-9199. Furthermore, a variety of online resources are available at <a href="http://www.uspto.gov/main/patents.htm">http://www.uspto.gov/main/patents.htm</a>

On		
Ted Kim	Telephone	571-272-4829
Primary Examiner	Fax (Regular)	703-872-9306
April 26, 2005	Fax (After Final)	703-872-9306
Technology Center 3700 Receptionist	Telephone	703-308-0861
Patents Assistance Center	Telephone	800-786-9199



